

Osaühing Raven soojusenergia temperatuurigraafik

Aruküla katlamaja kaugküttepiirkonnas

Välisõhu temp. °C	Väljuva küttevee temp. °C	Tagastuva küttevee temp. °C	Δt °C
8	40	34	6
7	41	34	7
6	42	35	7
5	43	35	8
4	44	36	8
3	45	37	8
2	46	37	9
1	47	38	9
0	48	38	10
-1	49	39	10
-2	50	39	11
-3	51	40	11
-4	53	41	12
-5	54	42	12
-6	55	43	12
-7	56	43	13
-8	57	44	13
-9	57	44	13
-10	58	45	13
-11	59	45	14
-12	60	45	15
-13	61	45	16
-14	62	46	16
-15	63	46	17
-16	63	47	16
-17	64	47	17
-18	65	48	17
-19	66	48	18
-20	67	48	19
-21	67	49	18
-22	68	49	19
-23	68	50	18
-24	69	50	19
-25	71	50	21
-26	71	51	20
-27	72	51	21
-28	73	51	22
-29	74	52	22
-30	74	52	22